



<u>EAST</u>







EAST (TOILET) 3

- 1. P3200, ELECTRONIC LAVATORY, MAY BE USED INSTEAD OF P3100, LAVATORY. FOR THE P3200 PROVIDE EITHER BATTERY POWER OR HARD WIRED CONNECTION.
- 2. PROVIDE A5109, GRAB BAR, THAT COMPLIES WITH ADA.
 3. TOILET NOT REQUIRED FOR RADIOGRAPHY ROOMS WITHOUT FLUOROSCOPY.

General Notes:

- 1. For typical equipment mounting heights see "TYPICAL EQUIPMENT MOUNTING HEIGHTS" drawing.
- 2. MIL-STD-1691 data can only be accessed from the Equipment Plan.

XRAY, RADIOGRAPHIC/FLUOROSCOPIC & TOILET, UNISEX (XDRF1/TLTU1)

RADIOLOGY/NUCLEAR MEDICINE		0	1000	2000
ELEVATIONS	35.13 NSM (378 NSF)			
DATE: 01/28/2002		1:50 S	CALE (MILLIN	METERS)